

GENERIC COOLING CAPACITIES TABLE AT 400 CFM PER TON AND 60°F EVAPORATOR ENTERING WET BULB

OUTSIDE AIR DRY BULB	TONS						
	1 1/2	2	2 1/2	3	3 1/2	4	5
60°F	17,900	23,900	29,900	35,900	41,900	47,800	59,800
65°F	17,500	23,300	29,200	35,000	40,800	46,700	58,300
70°F	17,100	22,800	28,400	34,100	39,800	45,500	56,900
75°F	16,600	22,200	27,700	33,300	38,800	44,400	55,500
80°F	16,200	21,600	27,000	32,500	37,900	43,300	54,100
85°F	15,800	21,100	26,400	31,600	36,900	42,200	52,700
90°F	15,400	20,600	25,700	30,900	36,000	41,100	51,400
95°F	15,000	20,100	25,100	30,100	35,100	40,100	50,100
100°F	14,700	19,500	24,400	29,300	34,200	39,100	48,900
105°F	14,300	19,100	23,800	28,600	33,300	38,100	47,600
110°F	13,900	18,600	23,200	27,900	32,500	37,100	46,400